



Certificate of Compliance

This certificate is issued for the following:

Pipe Hanger Components for Automatic Sprinkler Systems

Drop-in Anchor Models HE-HO and HE-CL

(see attached details)

Prepared for:

Técnicas Expansivas S.L.
Polígono la Portalada II, C/ Segador 13
26006, Logroño, La Rioja
Spain

FM Approvals Class: 1952 (December 2016)

Approval Identification: PR459590

Approval Granted: June 18, 2021

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read 'D.B. Fuller', written over a horizontal line.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group





Certificate of Compliance

Model No	Description	Hanger Rod Size, in (mm)	Nominal Pipe Size		Remarks
			in	(mm)	
HE-HO	Drop-in Anchor	(10)	3/4 through 4	(20 through 100)	-
HE-HO	Drop-in Anchor	(12)	5, 6, 8	(125, 150, 200)	-
HE-HO	Drop-in Anchor	(16)	10, 12	(250, 300)	-
HE-CL	Drop-in Anchor	(10)	3/4 through 4	(20 through 100)	-
HE-CL	Drop-in Anchor	(12)	5, 6, 8	(125, 150, 200)	-
HE-CL	Drop-in Anchor	(16)	10, 12	(250, 300)	-



Member of the FM Global Group